



Date: \_\_\_\_\_

Property Owner Name: \_\_\_\_\_

Property Address: \_\_\_\_\_

Check one of the following:

3 Year Maintenance Assessment

**OR** Septic Pumping Record

**TANK ASSESSMENT**

**Yes No**

Scum 3" or less from outlet baffle		
Sludge 12" or less from outlet baffle		
Is total sludge and scum volume greater than 25% of tanks liquid capacity		

**\*\*If you answered yes to any of the above, the tank needs to be pumped\*\***

What type of measurement device was used? \_\_\_\_\_

Tank Leak Assessment Liquid: Below Normal                      Normal                      Above Normal

Condition of Baffles:    Good                      Needs Replacement

If tank assessment was completed by homeowner, homeowner must sign:

Signature: \_\_\_\_\_ Phone: \_\_\_\_\_

**PUMPING INFORMATION:**

How many gallons of septage were removed?

Tank #1 \_\_\_\_\_ Tank #2 \_\_\_\_\_ Pretreatment Tank: \_\_\_\_\_ Pump Tank: \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\*Note: All sludge and liquids must be removed by pumping through the 24" maintenance hole. Removal from any location other than the 24" maintenance hole is not a compliant method of removal per MN Rules 7080.2450

**PUMPING CONTRACTOR INFORMATION:**

Company \_\_\_\_\_ MPCA # \_\_\_\_\_

Phone: \_\_\_\_\_ Email: \_\_\_\_\_

**-THIS IS NOT A COMPLIANCE INSPECTION-**